

Meter Pit Description

1. A Brass or other approved material, saddle is required to be installed on the water main based on size with a 1inch tap.
2. A 1inch brass Corp stop is required to be installed.
3. 1 inch CTS piping, polyethylene rated at 200 PSI grade tubing, or k-type roll copper is required for any connections leading to and from the meter pit. Indoor copper will not be permitted.
4. Curb stop is required to be installed no more than 3feet from meter pit.
5. Meter setter requirements, 3/4-5/8 copper setter, or a yolk with expansion wheel style setter consisting of a shutoff valve and check valve.
6. The meter pit must be 30 inches in height with a metal collar and lid, the lid must have a hole for antenna installation.

